

AB Tip İnceleme Sertifikası **EU Type-Examination Certificate**

Belge No / Certificate No

: 36-20-01-R03

Belgelendirme Tarihi - Bir Sonraki Belge Tarihi /

Certification Date / Certificate Validity Date : 05.01.2021-01.09.2025 Belge Geçerlilik Tarihi / Document Validity Period: 5 yıl / 5 years

Firma Unvanı ve Adresi / Company Name and Address

: ORJİN Sağlık Ürünleri Medikal Tekstil Turizm İnşaat

San. Ve Tic. Ltd. Şti.

6118 Sokak No: 9 Egemenlik Mah. Bornova/ İZMİR

Ürün Adı /Modeller / Product Name / Models Direktifi / Directive

Modülü/Kategori / Module / Category

: ORJÍN 1232

: 2016/425 REGULATION

: MNA M-2020-00250

: B MODÜLÜ/ KATEGORİ III MODULE B / CATEGORY III

Test Rapor No/ları / Test Report No Ürün Tipi / Product Type:

EN 149:2001+ A1:2009 Solunumla ilgili koruyucu cihazlar - Parçacıklara karşı koruma amaçlı filtreli yarım maskeler/ Respiratory protective devices - Filtering half masks to protect against particles

Ürünün Malzeme Bilgisi / Product Material Information: ORJIN 1232 model ürünleri kumaş, elastik kayış, burun klipsi ve filtre katmanı kullanılarak imal edilmiştir./ ORJİN 1232 model products are manufactured using fabric, elastic strap, nose clip, filter layer.

Revizyon nedeni/ Reason for revision: Model adı revize edilmiştir./ The model name has been revised.

Volkan AKIN 05.01.2021 Karar Verici / Approver

Okan AKEL 05.01.2021 Şirket Müdürü / General manager







MNA Laboratuvarları San. Tic.Ltd .Şti Adres: Küçükbakkalköy Mahallesi Yenidoğan Cad.No:21 Ataşehir/İstanbul Tel: 0216 574 07 08 Faks: 0216 575 13 31 www.mnalab.com



ATTACHMENTS (36-20-01-R03)

To certify the PPE product at Category III level, C2 or D module is accompanied by applying one of the conformity assessment methods along with the EU Type Examination (Module B).

Model: ORJÍN 1232

PPE SPECIFICATION	PERFORMANCE LEVELS
Classification	FFP2
Reusable / Single Shift Use	NR

PPE produced as a single unit to fit an individual user, all the necessary instructions for manufacturing such PPE on the basis of the approved basic model:

MARKING

MANUFACTURER: ORJİN Sağlık Ürünleri Medikal Tekstil Turizm İnşaat San. Ve Tic. Ltd. Şti.

PPE TYPE:

 EN 149:2001+ A1:2009 Respiratory protective devices - Filtering half masks to protect against particles

MODEL: ORJÍN 1232

PICTOGRAM AND PERFORMANCE LEVELS:

EN 149:2001+ A1:2009 FFP2 NR



NB 2841











Or Condition of Storage

MNA LABORATORIES SAN. TIC. LTD. \$TI declares that the above-mentioned product meets the requirements of the directive according to the EU Directive 2016/425, the safety of the product is covered by the conditions and use specified in this certificate and in the technical file.

MNA LABORATUVARLARI



TECHNICAL EVALUATION REPORT (36-20-01-R03)

7. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

- A visual inspection was made according to EN 149:2001 +A1:2009 for ergonomics.
- Protection levels and degrees are defined by the manufacturer.
- Suitable construction materials were determined by visual inspection according to EN 149:2001 +A1:2009.
- Respiratory protective dimensions are evaluated according to EN 149:2001 +A1:2009.
- Conditioning EN 149:2001 +A1:2009 part 8.3, Penetration EN 149:2001 +A1:2009 part 8.11 (EN 13274-7), Application performance EN 149:2001 +A1:2009 part 8.4, Inward leakage EN 149:2001 +A1:2009 part 8.5, Flammability EN 149:2001 +A1:2009 part 8.6, The carbon dioxide content of the inhaled air EN 149:2001 +A1:2009 part 8.7, Inhalation resistance EN 149:2001 +A1:2009 part 8.9, Exhalation resistance EN 149:2001 +A1:2009 part 8.9 has been tested and evaluated.

8. ANALYSIS AND EVALUATIONS:

EN 149:2001 +A1:2009

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Visual inspection	Shall also the markin supplied by the manu	_		mation	Appropriate		PASS
Total inward	At least 46 out of the 50 individual exercise result	<25	<11	<5	See the table below	FFP2	PASS
leakage	At least 8 out of the 10 individual wearer arithmetic means	<22	<8	<2	See the table below	FFP2	PASS

Total Inward Leakage (%)								
	Exercise 1	Exercise 2	Exercise 3	Exercise 4	Exercise 5	Average		
Subject 1 (As recieved)	5.1	5.0	4.9	5.1	5.1	5.0		
Subject 2 (As recieved)	5.0	5.1	5.1	4.9	5.1	5.0		
Subject 3 (As recieved)	5.0	4.9	5.0	5.0	5.1	5.0		
Subject 4 (As recieved)	5.0	5.0	5.3	5.1	5.0	5.1		
Subject 5 (As recieved)	5.1	5.0	5.0	4.8	4.9	5.0		
Subject 6 (After temperature conditioning)	5.0	5.1	5.2	5.1	5.1	5.1		
Subject 7 (After temperature conditioning)	5.2	4.9	5.1	5.1	4.9	5.0		
Subject 8 (After temperature conditioning)	5.0	5.1	5.1	5.0	5.1	5.1		
Subject 9 (After temperature conditioning)	5.0	5.0	5.0	5.1	5.1	5.0		
Subject 10 (After temperature conditioning)	5.3	5.1	5.1	5.1	5.1	5.1		



MNA LABORATUVARLARI

TECHNICAL EVALUATION REPORT (36-20-01-R03)

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Flammibility	Mask shall not burn burn for more than 5	or not to continue to		Flame not seen		PASS	
Carbondioxide content of the inhalation air	Shall not exceed an av	ot exceed an average of % 1				-	PASS
Penetration of filter material	Sodium chloride, 95 L/min %, max	% 20	% 6	% 1	See the table below	FFP2	PASS
	Paraffin oil, 95 L/min %, max	% 20	% 6	% 1	See the table below	FFP2	PASS

Penetration of filter material	Sodium Chloride (%)	Paraffin Oil (%)	
As recieved	4.7	4.4	
As recieved	4.3	4.7	
As recieved	4.9	4.6	
After the simulated wearing treatment	4.8	4.8	
After the simulated wearing treatment	5.0	4.6	
After the simulated wearing treatment	4.8	4.8	
Mechanical strength and temperature conditioning	5.0	4.9	
Mechanical strength and temperature conditioning	4.6	4.9	
Mechanical strength and temperature conditioning	4.9	4.6	

TESTS	PARAMETER	PERFO LEVELS	RMANC	Œ	RESULTS	PERFORMANCE LEVELS	EVALUATION	
		FFP1	FFP2	FFP3				
Compatibility with skin		known to be likely to y other adverse effect		Appropriate	-	PASS		
Head harness	It can be donned and	removed easily			Appropriate	-	PASS	
Breathing Resistance	Inhalation 30L/min	0,6 mbar	0,7 mbar	1 mbar	See the table below	FFP2	PASS	
	Inhalation 95L/min	2,1 mbar	2,4 mbar	3 mbar	See the table below	FFP2	PASS	
	Exhalation 160L/min	3 3 3 mbar mbar mbar			See the table below	FFP2	PASS	

Breathing Resistance	Inhalation 30L/min	Inhalation 95L/min	
As recieved	0.5	2.1	
As recieved	0.4	2.1	
As recieved	0.4	2.0	



MNA LABORATUVARLARI

TECHNICAL EVALUATION REPORT (36-20-01-R03)

After temperature conditioning	0.4	2.1
After temperature conditioning	0.5	2.0
After temperature conditioning	0.5	2.0
After the simulated wearing treatment	0.5	2.0
After the simulated wearing treatment	0.4	2.1
After the simulated wearing treatment	0.4	2.0

Breathing Resistance 160L/min	Facing directly ahead	Facing vertically upwards	Facing vertically downwards	Lying on the left side	Lying on the right side
As recieved	2,7	2,7	2,7	2,7	2,7
As recieved	2,6	2,7	2,7	2,7	2,7
As recieved	2,7	2,7	2,6	2,6	2,6
After temperature conditioning	2,6	2,6	2,7	2,7	2,7
After temperature conditioning	2,7	2,7	2,7	2,7	2,6
After temperature conditioning	2,7	2,6	2,7	2,7	2,7
After the simulated wearing treatment	2,7	2,7	2,7	2,6	2,6
After the simulated wearing treatment	2,7	2,7	2,7	2,7	2,7
After the simulated wearing treatment	2,7	2,7	2,7	2,7	2,7

9. DECISION PROPOSAL

Analysis and examinations ORJİN 1232 model coded personal protective equipment; Respiratory Protective Devices EN 149:2001 +A1:2009- Filtered Half Masks for Protection Against Particles - Properties, Experiments and Marking standards are evaluated. It is recommended to be certified at the performance levels specified as a result of technical evaluations.

10. ATTACHMENTS

- Basic Health Safety Requirements
- Risk Assessment
- Test Reports
- User Instruction

Reason for revision : The model name has been revised.

CONTROLLER : VOLKAN AKIN

SING :

DATE : 05.01.2021